

<u>ROW CHECKLIST</u>	CHECK
<u>STANDARD ITEMS</u>	<input type="checkbox"/>
- Locality Plan	<input type="checkbox"/>
- Allotment Number and Boundary Specifications and Dimensions	<input type="checkbox"/>
- Existing Driveways, Existing Services, any Existing Drainage Pipes or Pits and House Drain Outlets	<input type="checkbox"/>
- Typical ROW Cross-Section Scale 1:10	<input type="checkbox"/>
- Dial Before You Dig (1100) Information	<input type="checkbox"/>
- Dial Before You Dig (1100) Warning	<input type="checkbox"/>
- North Direction	<input type="checkbox"/>
- Setout Line Information	<input type="checkbox"/>
- Temporary Benchmarks (TBM)	<input type="checkbox"/>
- Drainage Longitudinal Section	<input type="checkbox"/>
- Cross-Sections of Chainages Minimum at every 5m Intervals and at Significant Locations	<input type="checkbox"/>
- ROW Longitudinal Section	<input type="checkbox"/>
- Pit Schedule (Grated Pits with Galvanised Hinged Lockable Bike Safe Class D "V" Grates)	<input type="checkbox"/>
- Midpoint IL must be 75mm lower than the Top Lower Side	<input type="checkbox"/>
- Dowelled Contraction Joint at every 6m	<input type="checkbox"/>
- Proposed Levels are to be lower or equal to Existing Cross-over	<input type="checkbox"/>
- Min. 225mm Pipe, R.C Class 2, Rubber Ring Jointed	<input type="checkbox"/>
- Min. Cover 600mm and Pipe Grade Minimum 1:200	<input type="checkbox"/>
- Typical Right of Way Cross-Section Detail – Refer to Standard DWG DS6	<input type="checkbox"/>
- General Notes on Standard Drawing	<input type="checkbox"/>